COLLECTION OF CIG-OSM/IN DECISIONS

Standard:	EN 50086-2-4:1994	Sub clause:	General	Sheet no. OS	SM/IN 023b
				Page 1(1)	
Subject:	Testing programme for a range of conduit sizes	Key words:	Testing program me	Meeting no.	9 6.25 6.6

Question: Need of Testing programme for uniform ranges of conduit sizes?

Decision: When it is presented for testing a range of conduit sizes the testing programme shall be according the following table

Size	First colour	Other colours	
1	Full test	Clauses 8-10.2-10.3	
2	Clauses 8-10.2-10.3-10.4-10.6-12	None	
3	Clauses 8-10.2-10.3-12.1	None	
*n:2	Full test (A)	Clauses 8-10.2-10.3(B)	
n-1	Clauses 8-10.2-10.3-10.4-10.6-12	None	
n	Full test	Clauses 8-10.2-10.3	

* If there are less than five sizes in the range, the full tests programme (A) of the n:2 (central size) is replaced by the limited programme (B). When n:2 size is not a single size (i.e. there are two such sizes when considering an even number of sizes) the n:2 test could be carried out on one of the two sizes or distributed between them.

Explanatory notes: